



WEST VIRGINIA DEPARTMENT OF HEALTH

PERMIT



OWNER: Steven Greenwood and DRILLER: Jerry Adams

are hereby issued a permit to construct a well located
(Construct, Modify or Abandon)

at Capon Bridge, right on River Rd., go 4 1/2 miles to white two-story house with green roof and shutters, on left

in accordance with Chapter 16, Article 1, Section 9 of the Code of West Virginia.

Date Issued September 6, 1994

[Signature]
Issuing Officer

Sanitarian
Title

Expires September 6, 1995

Hampshire
County Health Department

Permit No. DW-14-09-95-053

This permit is not transferable and any change of information submitted in application dated Sept. 2, 1994 will automatically render this permit invalid.

Please draw a sketch of the property showing existing or proposed well location, location of structures, existing or proposed sewage systems within 200 feet of well location, slope of site and lot dimensions. Locate animal pens, barnyards or any other factors which can be a possible source of contamination for the water supply.



House



Water Supply



Percolation Test Site



Soil Absorption Line



Dir. of Ground Slope



Property Line




Trees



Septic Tank



Mobilehome



WEST VIRGINIA STATE DEPARTMENT OF HEALTH
Office of Environmental Health Services
ENVIRONMENTAL ENGINEERING DIVISION

WELL COMPLETION REPORT

WV 9-22-94
Date(s) Sept 8, 1994 County Hampshire Permit #: DW 14-09-95-053
Town: Capon Bridge Area Name/Location Right on Riker Rd. 4.5 mi white house w/green Roof
Well Owner: Steven Greenwood Address: 1930 New Hampshire Ave. Apt 48
Telephone Number: 703 525-7874 Washington, DC 20009
Well Driller: Serry W Adams Address: P.O. Box 952
Telephone Number: 304 822-4092 Romney, WV 26757

WELL LOG

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
0-48'	SAND & Clay - Unconsolidated	Type of Well: <u>D/W</u> Drilling Method: <u>Air Rotary Hammer</u>
48'	Sandstone - Consolidated	Well Diameter: <u>5 1/2"</u> Casing O.D.: <u>6-5/8"</u>
58'	Sandstone - Consolidated	Well Depth: <u>120</u> Date Completed: <u>Sept 8, 94</u>
	Set Casing - GROUT	CASING: Length <u>59</u> Feet Height above ground <u>1</u> Feet
85'	Brown Sandstone	<input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Cast Iron
	Consolidated - Water 5 GPM	Other _____ Type _____
104'	Brown Sandstone	
	Consolidated - Water 25 GPM	SCREEN
120'	Brown Sandstone	<input type="checkbox"/> None Installed
	Consolidated - Test Well	Type _____ Diameter _____
	Yield - Stopped Drilling Operation	Slot/Gauge _____ Length _____
		Set Between _____ Ft. and _____ Ft.

PUMPING OR BAILING TEST

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>overflowing</u>		
Pumping Rate (GPM)	<u>30</u>		
Pumping Level (Ft. Below Grade)	<u>100</u>		
Duration of Test (In Hours)	<u>1/2</u>		
Recovery Time to Static Level (In Hours)	<u>1/2</u>		

WELL HEAD

Pitless Adapter: Type, Make, Etc. To be installed w/Pump System
Well Cap: Type, Make, Etc. Royer 6-5/8" Conduit - Type
Well Seal: Type, Make, Etc. _____
Well Platform:
Length _____ Width _____ Thickness _____
Grouting: Yes No
All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

Serry W Adams 004
Name Certification No.
A & S Well Drilling
Registered Business Name
Serry W Adams Sept 8, 1994
Signed Date